



AIUB DSpace Publication Details

Title:	Stabilization Control of Power System with Large-Scale Wind Farm by Using DFIG Considering Grid Codes
Author(s) Name:	Md. Rifat Hazari, Effat Jahan, Chowdhury Akram Hossain, Mohammad Abdul Mannan, Atsushi Umemura, Rion Takahashi and Junji Tamura
Contact Email(s):	mdmannan@aiub.edu
Published Conference Name:	2019 International Conference on Robotics, Electrical and Signal Processing Techniques (ICREST)
Type of Publication:	International Conference
Volume:	_____ Issue _____
Publisher:	IEEE
Publication Date:	February 21, 2019
ISSN:	_____
DOI:	https://doi.org/10.1109/ICREST.2019.8644524
URL:	https://ieeexplore.ieee.org/document/8644524
Other Related Info.:	Paper ID: 20169

Citation: Md. Rifat Hazari, Effat Jahan, Chowdhury Akram Hossain, Mohammad Abdul Mannan, Atsushi Umemura, Rion Takahashi and Junji Tamura, “Stabilization Control of Power System with Large-Scale Wind Farm by Using DFIG Considering Grid Codes,” Proceedings on International Conference on



AIUB DSpace Publication Details

Robotics, Electrical and Signal Processing Techniques (ICREST), American International University-Bangladesh (AIUB), Dhaka, Bangladesh, Paper ID: 20169, January 2019.

Abstract:

This paper proposes an innovative operational scheme for a grid-connected large-scale wind farm (WF) which is composed of both fixed speed wind turbines with squirrel cage induction generators (FSWT-SCIGs) and variable speed wind turbine with doubly fed induction generators (VSWT-DFIGs). Normally, SCIG cannot fulfil the necessities of fault ride-through (FRT), because of the insufficient amount of reactive power supply during transient condition which may leads to the instability of the power system. Thus, in this paper, a new technique is proposed to stabilize SCIG by using DFIG in a grid-connected WF. A novel fuzzy logic controller (FLC) based rotor side controller is proposed for VSWT-DFIG to improve the FRT capability of FSWT-SCIG-based WF and transient stability of entire power system. The proposed FLC is designed in order to inject effective amount of reactive power during fault condition. The effectiveness of the proposed control strategy is verified through simulation analyses on a multi-machine power system model in PSCAD/EMTDC software. Additionally, the transient stability of the entire power system is evaluated by using the transient stability index.

Keywords: DFIG, SCIG, Transient Stability, Fuzzy Logic Controller and Power System